

MISSION SUPPORT AND TEST SERVICES, LLC

UNDER PRIME CONTRACT DE-NA0003624 WITH THE UNITED STATES OF AMERICA ACTING THROUGH
THE UNITED STATES DEPARTMENT OF ENERGY
POST OFFICE BOX 98521
LAS VEGAS, NV 89193-8521

REQUEST FOR PROPOSAL

DATE OF AMENDMENT: 09/18/2025

RFP NUMBER: SOL-0001153

IMPORTANT: PROPOSALS WILL BE RECEIVED UNTIL October 1st, 2025, 12:00PM PST LOCAL TIME. PROPOSALS ARE TO BE PROVIDED AS DETAILED IN THE REQUEST FOR PROPOSAL.

INQUIRIES SHOULD BE DIRECTED TO: Calvin Callahan, MISSION SUPPORT AND TEST SERVICES, LLC, NORTH LAS VEGAS, NEVADA, TELEPHONE NUMBER (509) 793-6963, Email; Callahcd@nv.doe.gov. IF SUCH INQUIRIES ARE OF A COMPLEX NATURE OR SCOPE, THEY SHOULD BE IN WRITING.

AMENDMENT NO. 01

SUBJECT REQUEST FOR PROPOSAL No. SOL-0001153, DATED: 08/25/2025 FOR the purchase of Commercial Steel Door Replacement at RSL-Nellis IS HEREBY AMENDED AS FOLLOWS:

1. *The due date is extended to Wednesday, October 1st, 2025, at 12:00PM PST.*
2. *Questions for this solicitation will now be accepted until Wednesday, September 24th, 2025, at 12:00PM PST.*
3. *Updates to the Statement of Work were made. Current Revision of the SOW is Rev. 02. See attached.*
4. *Responses to questions are as follows:*
 - a. Can you specify which color paint is to be used for the doors?
 - i. *Doors are to be painted with semi-gloss and acrylic enamel to match the existing doors (color sample will be provided). Color to be provided at a later time.*
 - b. Can you confirm that all hardware is to remain on the doors except the hinges, which shall be replaced with existing type?
 - i. *Yes, everything but the hinges will be transferred.*
 - c. Can you confirm that including the door, the frame and all hardware is to also be replaced on door XD-27 due to its poor condition?
 - i. *Yes, combination of frames, doors and hinges on XD-18 & XD-27 only. TSB doors are doors and hinges only. All other hardware is to be transferred and yes, it is known there are parts missing off the left door latch assembly on XD-27.*
 - d. It was mentioned that Mortis type doors would be preferred, can you confirm if having Mortis capable doors is the intent and which doors should have this capability?
 - i. *All doors appear to be Mortise prep type and the decision was made to keep them that way.*
5. *All else remains unchanged.*

When submitting your proposal, please acknowledge receipt of this amendment by indicating on the Offeror's Proposal Letter the number of amendments.